



MUNICIPAL CORPORATION OF DELHI
(PUBLIC HEALTH DEPARTMENT: CIVIL LINES ZONE)
16, RAJ PUR ROAD, DELHI – 110054



DHO/CLZ/2025/.....16/6

Dated:-29/10/25

SCHOOL HEALTH CERTIFICATE


It is certified that an inspection team headed by public health inspector Civil Lines Zone from Public Health Department, inspected the **M/S Rani Public Sr. Sec. School situated at A-1 Block, Sant Nagar, Burari Road, Delhi- 110084** on 29.10.2025 and found that the school is running under sanitary and hygienic conditions from health point of view.

School has safe drinking water facilities for the students and members of staff of the institution and maintaining the hygiene and sanitation condition in the school building and the campus.

The above certificate is valid for 1 year from date of issue.

Manager,

M/S Rani Public Sr. Sec. School
at A-1 Block, Sant Nagar, Burari Road,
Delhi- 110084


Dy. Health Officer
Civil Lines Zone

Deputy Health Officer
Civil Lines Zone
Municipal Corporation of Delhi
16, Rajpur Road, Delhi-110054



DELHI JAL BOARD: GNCTD
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54



TEST REPORT

Sample ID	Ref. No. D.J.B/DTQC/Wzd./2026-27/Paid/53-54		
Location /Address of Sample	Rani Public Sr. Sec. School, A-1, Block, Sant Nagar, Burari Road, Delhi-110084.		
Letter Reference No.	RPS/297/25-26	Ref. Letter Date	29.05.2026
Challan No.	71	Challan Date	01.06.2026
Sample Collection date	03.06.2026	Analysis start date	03.06.2026
Any other Information		Analysis end date	06.06.2026
		Reporting date	09.06.2026

TEST RESULTS

S.No	Parameters	Unit	As per the IS 10500		Inlet (From Storage tank)	Outlet
			Acceptable limit	Permissible limit		
1	Colour	CU	5(Max)	15(Max)	2.0	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	3.8	1.0
4	pH Value at 25 °C	--	6.5-8.5	No relaxation	7.38	7.66
5	Electrical Conductivity	µS/cm	-	-	354	327
6	Total Dissolved Solids	mg/L	500(Max)	2000(Max)	230	213
7	Total Alkalinity as CaCO ₃	mg/L	200(Max)	600(Max)	70	60
8	Total Hardness as CaCO ₃	mg/L	200(Max)	600(Max)	124	106
9	Calcium as Ca	mg/L	75(Max)	200(Max)	38	30
10	Magnesium as Mg	mg/L	30(Max)	100(Max)	7.2	7.7
11	Iron as Fe	mg/L	1.0(Max)	No relaxation	0.12	0.10
12	Chloride as Cl	mg/L	250(Max)	1000(Max)	43	50
13	Fluoride as F	mg/L	1.0(Max)	1.5(Max)	1.33	0.69
14	Ammonical-Nitrogen	mg/L	0.5(Max)	No relaxation	BDL	BDL
15	Nitrate as NO ₃	mg/L	45(Max)	No relaxation	3.9	2.9
16	Sulphate as SO ₄	mg/L	200(Max)	400(Max)	55	37
17	Residual Chlorine	mg/L	0.2(Min.)	1.0(Max)	BDL	BDL
18	Coliform Count 37°C (MPN)	/100 mL	Absent	No relaxation	0	0

*BDL=Below Detection Limit

.....End of Report.....

Remarks: Samples collected conforms specification for tested parameters and can be considered for the drinking purpose.

Tested by
Lab.Tech.

Verified for Chemical parameters
Asstt. Chemist

Verified for MPN
Bacteriologist

Authorized by
Chemist

ACWA(WZD)
Asstt. Chief Water Analyst
D.J.B. (Govt. of N.C.T. of Delhi)
Water Works, Wazirabad